



TRILUX
SIMPLIFY YOUR LIGHT.

LIVELINK ONE

EN QUICK START GUIDE



10334326 | 231006

**CONTENT**

Safety information	03
Install the LiveLink One app	04
Connect with LiveLink network	05
Registration	06
Overview	07
Devices	10
Groups – luminaire groups	11
Groups – sensors	14
Groups – pushbuttons	16
Scenes	18
General settings	21



FOR YOUR SAFETY

Explanation of the warning levels

Observe and follow the warnings. Failure to observe the warnings may result in damage to property or malfunctions!



NOTICE. Indicates dangers which can result in material damage or malfunctions.



TIP. Indicates information containing advice or a useful note.

Explanation of instructional pictograms



Short press

Tap the screen briefly with your finger to trigger the action.



Long press

Tap and hold your finger on the screen to trigger the action.



EN

LIVELINK ONE

INSTALL THE LIVELINK ONE APP



Scan

Link

<https://apps.apple.com/de/app/livellink-one/id1621987669>

Scan

Link


<https://play.google.com/store/apps/details?id=com.trilux.livellink>



CONNECT WITH LIVELINK NETWORK



Allow the app to access location data and network access in order to use it.



1.

LiveLink
Wi-Fi

Select the system in
the system settings of
the end device

2.


LiveLink
Wi-Fi password
enter: livelink

3.

Open the
LiveLink ONE
app



REGISTRATION





OVERVIEW



The following settings are preconfigured:

- All luminaires are combined into luminaire group G1
- Luminaire group G1 is switched on with the connected sensors depending on movement (with follow-up time 10 minutes) and controlled according to daylight (at 80% illuminance)
- TRILUX HCL curve for HCL luminaires is activated
- Luminaire group G1 can be dimmed and switched with the connected push-buttons




The selected menu item is highlighted red.



The status LED shows the connection to the controller.
Green: Connected
Red: Not connected




OVERVIEW





OVERVIEW







DEVICES



All available luminaires (TW= tunable white luminaire, D= dimmable luminaire, E= DALI emergency luminaire), sensors and push-buttons are displayed.



GROUPS – LUMINAIRE GROUPS



GROUPS – LUMINAIRE GROUPS

1. TW D E

Select desired luminaire(s) in the app (luminaire flashes to confirm)

2.

Add selected luminaire(s) to another group





Clicking on the magnifying glass starts automatic mode. This helps with assignment of the luminaires. (see p. 13)




GROUPS – LUMINAIRE GROUPS



When automatic mode is activated, the first luminaire flashes and can be added to a desired group. When this is done the second light flashes, and so on.



Activate
previous luminaire
(luminaire flashes).





Activate
next luminaire
(luminaire flashes).




GROUPS – SENSORS



When a movement is detected, the green symbol appears. 



GROUPS – SENSORS



GROUPS – PUSHBUTTONS

Assign a function to the desired push-button (see p. 17)

ASSIGN

+

Press the desired push-button

Assign a function to the corresponding preselected push-button (see p. 17)

GROUPS – PUSHBUTTONS

1. Input X (Terminal X)

Select the desired push-button



2. Function

Select the desired function





3.

Assign to a group or scene

SCENES




SCENES






SCENES



GENERAL SETTINGS



TRILUX GmbH & Co. KG

Heidestraße
D-59759 Arnsberg
+49 2932 301-0
info@trilux.com
www.trilux.com